

# Echo



1695mm x 600mm in White RAL 9016 with White Cylinder valves

# Echo shown on page 95

Steel; Side loading towel rail, 50mm x 10mm flat tubes  
Can be installed left or right handed  
CE approved & certified to BS EN442

White RAL 9016 as standard, 188 RAL Colours and 30 Special Finishes  
Please call **01342 302250** for a RAL or Special Finish chart

## Stock White RAL 9016: 48-72 Hours

Made to Order sizes & colours: Up to 7 weeks White & White Electric,  
Up to 8 weeks Colours

## Stock options White RAL 9016- Hydronic

Height (mm)	Width (mm)	Model	Watts Δt 50°C	Btu's Δt 50°C
850	500	ECHO8550	585	1996
1110	500	ECHO1150	764	2607

Made to order options - Hydronic

Height (mm)	Width (mm)	Model	Watts Δt 50°C	Btu's Δt 50°C
655	500	ECHO6550	450	1535
	600	ECHO6560	506	1726
850	600	ECHO8560	655	2235
1110	600	ECHO1160	857	2924
1695	500	ECHO1650	1167	3982
	600	ECHO1660	1310	4470

<b>Pipe centres left to right</b>
50mm
<b>Pipe centres from wall</b>
57mm - 65mm
<b>Depth from wall</b>
112mm - 120mm

\*Saving based on the value of individual items when bought separately. Order any of our selected valves & matching pipe covers at the same time as your radiator; PROMOV3W (white), PROMOV3C (chrome).



**SAVE MONEY!** WHEN YOU BUY OUR CYLINDER KIT WITH ANY TOWEL RAIL ORDER\* QUOTE **PROMOV3** AT TIME OF ORDER

Available in White or Chrome

Made to order options - Electric

Height (mm)	Width (mm)	Model	Watts Δt 50°C
850	500	ECHO8550EW	600
	600	ECHO8560EW	600
1110	500	ECHO1150EW	800
	600	ECHO1160EW	800
1695	500	ECHO1650EW	1200
	600	ECHO1660EW	1200

Supplied as standard with a MOA Element

- 5 heat settings from 30°C to 60°C regulating internal radiator temperature,
- denoted by 5 LEDs. No Timer.
- Compatible with external Timer as remembers settings when turned off
- 55mm diameter clock shaped face.
- 4x Buttons: Temperature +/-, Dryer, Power, Frost & overheating protection.
- Straight cable, no plug. IPx5. Class I. Guarantee - 2 years.

# Piano Lato shown on page 97

High quality Italian design & manufacture  
Steel; side loading towel rail  
UKCA approved & certified to BS EN442

White RAL 9016 as standard, 188 RAL Colours and 30 Special Finishes  
Please call **01342 302250** for a RAL or Special Finish chart

## Stock White RAL 9016: 48-72 Hours

Made to Order sizes & colours: Up to 5 weeks

Pipe centres left to right	Pipe centres from wall	Depth from wall
50mm	57mm - 67mm	80mm - 90mm

## Stock options White RAL 9016


Height (mm)	Width (mm)	Model	Watts Δt 50°C	Btu's Δt 50°C
1260	550	PIALAT1255	524	1788
1596	550	PIALAT1555	654	2231

\*Saving based on the value of individual items when bought separately. Order any of our selected valves & matching pipe covers at the same time as your radiator; PROMOV3W (white), PROMOV3C (chrome).



**SAVE MONEY!** WHEN YOU BUY OUR CYLINDER KIT WITH ANY TOWEL RAIL ORDER\* QUOTE **PROMOV3** AT TIME OF ORDER

Available in White or Chrome



## Technical Specifications

Materials	Steel
Connections	½" flow and return.
Test pressure	7.8 Bar
Testing authority	EN442
Maximum operating pressure	6 Bar
Maximum working temperature	95 °C
Packaging	Wrapped in polythene in cardboard box

**PLEASE NOTE:** Systems using micro bore pipework must have adequate pressure and flow rates for the number and style of radiators on the system.

## Terms & Conditions

All products must be inspected once removed from the packaging and The Radiator Company notified within 28 days of delivery of any scratches, blemishes or other damage. The Radiator Company will then replace the radiator.

Imperfect radiators should therefore not be fitted and The Radiator Company will not accept responsibility for replacement of scratched or damaged radiators once they have been fitted. This includes any consequential loss or cost of fitting.

If The Radiator Company are not notified within 28 days of the date on the signed delivery note then it will be deemed that The Radiator Company have fully complied with its obligations and claims will not be considered.

Failure to comply with any of the above may invalidate any claims.

We recommend that after you check the product on delivery that it is stored in its packaging to prevent damage prior to installation. The Radiator Company cannot accept responsibility for items damaged after delivery.

## Guarantees & Liabilities

As we are not the manufacturers of this product we will take all reasonable endeavours to make over to you the benefit of any warranty or guarantee given by the manufacturer, which is usually five years on most of our range. (Copies of specific guarantees for any of our products are available on request).

The guarantees in all cases are subject to the products being installed in accordance with British and or European standards as well as these fitting instructions. The guarantees in all cases are restricted to the free of charge replacement or repair of the failed product only. Our liability will under no circumstances extend beyond the repair or replacement of the product supplied by us. Claims for either labour in replacement or damage to property are not admissible. Any goods that are returned, in the event of a problem, will belong to The Radiator Company.

## Fittings Instructions



Please read these instructions and terms and conditions carefully prior to installation. Failure to do so may invalidate the warranty


The Radiator Company  
Units 13 - 14 Charlwoods Road  
East Grinstead  
West Sussex  
RH19 2HU




ECHO\_IR\_1.0

## Diagrams of Echo

Can be installed as a left- or right-handed version



### Bracket Positions



## Pipe Centres

Pipe centres left to right	50mm
Pipe centres from wall	57mm - 65mm
Depth from wall	112mm - 120mm

## 1 Unpack & Inspect

The Radiator Company prides itself on selecting products from manufacturers who exercise tight quality control measures. We only select models with excellent standards of welding and brazing, as well as high quality finishes.

All of our products are well packaged and should reach you in perfect condition. Just in case however, we offer a minimum 5-year no quibble guarantee for all radiators and towel rails.

Please carefully unpack and inspect this radiator and all fittings.

The Radiator Company must be notified of any shortages or damage within 28 days of delivery.



For further information please see terms and conditions on back page.

## 2 Contents

You should have:

- 1 Radiator
- 2 Wall bracket sleeves
- 1 Airvent
- 1 Blanking Plug

You will need:

- Tape measure
- Electric drill and bits
- Spirit level


## 3 Mark Bracket Positions

The fixing positions for the two top brackets are measured at 100mm down from the top of the collector and 100mm up from the bottom of the collector (please see diagram opposite).

In order to accurately mark the bottom bracket fixing positions we recommend you mark, fix and level the two top brackets first. Then hang the radiator, ensuring it is vertically level and manually hold the bottom brackets in position while marking.

## 4 Fix Brackets

Using a suitable drill bit, screws and plugs, fix the brackets sleeves to the wall and level with a spirit level. Please see diagrams.



### PLEASE NOTE :

It is essential that all brackets are level to ensure a vertical alignment for connecting the pipework.

## 5 Hang Radiator & Commission

With the brackets sleeves firmly fixed and level, slot the radiator into the sleeves and firmly fix by tightening the grub screws.

When securing the brackets, we suggest positioning the sleeves in a way which the top bracket's grub screw is facing upwards, and the bottom bracket's grub screw is facing down. This will improve the aesthetics of the radiator and avoid any screws being seen.

Please Note:

In accordance with Part L1 2006 of the Building Regulations and BS7593:1992 code of practice for the treatment of hot water and central heating systems, we strongly recommend flushing the heating system post installation of new radiators and then adding the correct quantity and type of inhibitor for use with your radiator and system to prevent corrosion. Damage caused to systems not protected by a suitable inhibitor will not be covered by manufacturer's guarantee.